

COMMUNITY COLLEGE OF ALLEGHENY COUNTY  
PURCHASING DEPARTMENT  
800 ALLEGHENY AVENUE, PITTSBURGH, PA 15233

**ADDENDUM 2**  
**BID PROPOSAL NO. 1135**  
**ADDITIONAL POWER AND COMPRESSED AIR FOR CEIT BUILDING**  
**DECEMBER 31, 2024**

The following additional information is hereby made a part of this bid:

\*\*\*\*\*

**Various questions and answers:**

From my pictures, the Existing are "Reel Craft" High Temp Hose reels.

*[BHE-JJS]* BHE did not specify the initial hose reels used but does have a photo that agrees with that manufacturer.

Since the piping is 1/2", am I safe to assume that 1/2" is the hose size?

*[BHE-JJS]* Correct. Most of the CA piping is 1/2in to all the drops and out to the equipment.

After looking at their website, They come in 50ft or 25ft, what length hose should we bid?

*[BHE-JJS]* For bidding purposes, use 25ft hose reels.

**End of Addendum 2**

\*\*\*\*\*

Sign addendum and return to the College with your response.

\_\_\_\_\_  
Company Name

\_\_\_\_\_  
Bidder's Signature